

MCC FRONT ELEVATION



MCC PLAN VIEW
ALL SECTIONS

MCC BILL OF MATERIAL

ITEM	QTY.	DESCRIPTION	CATALOG No.
1	1	1600A MLO, BOTTOM ENTRY	
2	1	1600A CRD 65KAIC/100% RATED BOTTOM FEED	
3			
4	1	50/50A HFD DUAL BRANCH CIRCUIT BREAKER DISCONNECT, 480 VAC	
5	1	35/20A HFD DUAL BRANCH CIRCUIT BREAKER DISCONNECT, 480 VAC	
6			
7			
8			
9	2	SIZE 1 FVNR STARTER WITH 7A HMCP DISCONNECT, 3.0 HP, 480 VAC, 120 VAC TRANSFORMER CONTROL PRIMARY/SECONDARY FUSING	
10	1	200A FVC STARTER WITH 250AF/200AT HJD C.B. DISCONNECT, 480 VAC, 120 VAC TRANSFORMER CONTROL, 3-POS. S.S., PILOT LIGHT & CONT FUSE	
11			
12			
13			
14			
15			
16			

SECT.NO.
SHOWN ON SHT.

DET NO
DET ON
SHT.TAKEN FROM

MOTOR CONTROL CENTER – SINGLE LINE
DWG NO
TITLE
REFERENCE DRAWING

TRITON TRANSFORMER

REV	BY	DATE	DESCRIPTION	APPD

MOTOR CONTROL CENTER
MCC B.O.M. & ELEVATION

SCALE FULL
DATE 02/25/22
DRAWN
LISBON, OH
CHECK
APPD.
PROJ.