



 <b>MEG ENERGY</b>	<b>CHRISTINA LAKE REGIONAL PROJECT</b> <b>Phase 3A EPC for Central Plant Facilities</b>  <b>SLI Project No. 511036</b>	 <b>SNC-LAVALIN</b>

 <b>SNC-LAVALIN</b>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30px; text-align: center;"><input type="checkbox"/> A1</td> <td>Not suitable to initiate fabrication. modify as noted, resubmit for review</td> </tr> <tr> <td style="text-align: center;"><input type="checkbox"/> B1</td> <td>Suitable to initiate fabrication as noted. modify as noted, resubmit for review</td> </tr> <tr> <td style="text-align: center;"><input type="checkbox"/> C1</td> <td>Suitable to fabricate to completion as noted. submit final documents including as-builts as required</td> </tr> <tr> <td style="text-align: center;"><input type="checkbox"/> D1</td> <td>Suitable to fabricate to completion. submit final documents including as-built documents as required</td> </tr> <tr> <td style="text-align: center;"><input type="checkbox"/> E1</td> <td>Not suitable as final documents as noted. modify as noted and resubmit.</td> </tr> <tr> <td style="text-align: center;"><input checked="" type="checkbox"/> F1</td> <td>Suitable as final documents. no further resubmittal required (unless revised by vendor)</td> </tr> </table>	<input type="checkbox"/> A1	Not suitable to initiate fabrication. modify as noted, resubmit for review	<input type="checkbox"/> B1	Suitable to initiate fabrication as noted. modify as noted, resubmit for review	<input type="checkbox"/> C1	Suitable to fabricate to completion as noted. submit final documents including as-builts as required	<input type="checkbox"/> D1	Suitable to fabricate to completion. submit final documents including as-built documents as required	<input type="checkbox"/> E1	Not suitable as final documents as noted. modify as noted and resubmit.	<input checked="" type="checkbox"/> F1	Suitable as final documents. no further resubmittal required (unless revised by vendor)
<input type="checkbox"/> A1	Not suitable to initiate fabrication. modify as noted, resubmit for review												
<input type="checkbox"/> B1	Suitable to initiate fabrication as noted. modify as noted, resubmit for review												
<input type="checkbox"/> C1	Suitable to fabricate to completion as noted. submit final documents including as-builts as required												
<input type="checkbox"/> D1	Suitable to fabricate to completion. submit final documents including as-built documents as required												
<input type="checkbox"/> E1	Not suitable as final documents as noted. modify as noted and resubmit.												
<input checked="" type="checkbox"/> F1	Suitable as final documents. no further resubmittal required (unless revised by vendor)												
Vendor's drawing review for conformity with specifications and design drawing.  This review does not relieve the vendor of his responsibility for errors in design and detailing as detailed in his contract.													
<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 35%;">Vendor: Sewon Cellontech Co. Ltd. - P00007</td> <td style="width: 30%;">No.: E0351-3AE325-P-02</td> <td style="width: 15%;">Rev: 2</td> <td style="width: 20%;">Date Rec'd 2013-10-02</td> </tr> <tr> <td colspan="4">Doc. Title: L53.51, L53.53 - THERMAL DESIGN CALCULATION - Tag:3A-E-325A/B</td> </tr> </table>		Vendor: Sewon Cellontech Co. Ltd. - P00007	No.: E0351-3AE325-P-02	Rev: 2	Date Rec'd 2013-10-02	Doc. Title: L53.51, L53.53 - THERMAL DESIGN CALCULATION - Tag:3A-E-325A/B							
Vendor: Sewon Cellontech Co. Ltd. - P00007	No.: E0351-3AE325-P-02	Rev: 2	Date Rec'd 2013-10-02										
Doc. Title: L53.51, L53.53 - THERMAL DESIGN CALCULATION - Tag:3A-E-325A/B													
Client Code:	Project: MEG Phase 3A EPC												
Reviewed by: <i>SS</i> Date: <i>2-oct-2013</i>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 70%;">Document No P-5310-01-0039</td> <td style="width: 30%;">Submittal 03</td> </tr> </table>	Document No P-5310-01-0039	Submittal 03										
Document No P-5310-01-0039	Submittal 03												

 <b>SEWON CELLONTECH</b>	<b>DOCUMENT FOR EQUIPMENT</b>	SWC JOB NO	E-0351
		ITEM NO.	3A-E-325A/B
		SWC DOC. NO.	E0351-3AE325-P-02

ASME-U

 <b>MEG Energy Corp.</b>		 <b>SNC • LAVALIN</b>	
<b>P.O NO.</b>	<b>P-5310-01</b>		
<b>PROJECT NAME</b>	<b>CLRP Phase 3A Central Plant Facility: EPC</b>		
<b>PROJECT NO.</b>	<b>511036</b>		
<b>DOCUMENT TITLE</b>	<b>THERMAL DESIGN CALCULATION</b>		
<b>ITEM NO.</b>	<b>ITEM DESCRIPTION</b>		
<b>3A-E-325A/B</b>	<b>BLOWDOWN DISPOSAL / GLYCOL EXCHANGER</b>		



- Total Sheet : 24 Sheet (Including This Cover)

2	<i>M.K. Park</i> 9/26/13	<i>T.W. Kim</i> 9/27/13	<i>Y.S. Ji</i> 9/27/2013	THIRD ISSUE
1	M.K.PARK	T.W.KIM	Y.S.JI	SECOND ISSUED
0	M.K.PARK	T.W.KIM	Y.S.JI	FIRST ISSUED
REV	PREPARED BY	REVIEWED BY	APPROVED BY	DESCRIPTION

**SEWON CELLONTECH CO.,LTD.**



**SEWON CELLONTECH****TUBULAR HEAT EXCHANGER**

SHEET 2 OF 21

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Blowdown Disposal / Glycol Exchanger	2	-	-	-	09-26-2013
ITEM NO.	3A-E-325A/B (Max Duty Case)					

Total	2	Shells, Connected in	1	Parallel	2	Series Shells	Install	<input checked="" type="checkbox"/> Hor. <input type="checkbox"/> Vert.	Size	1,120.0 ID - 6,096.0 L
Code	ASME Sec.VIII Div.1 (STAMP), TEMA, API660	TEMA Type	AFU (Note 13)	TEMA Class	R	Effective Area	301.34	m <sup>2</sup> /Shell		

**PERFORMANCE OF ONE BATTERY**

PERFORMANCE OF ONE BATTERY											
				SHELL SIDE				TUBE SIDE			
				INLET		OUTLET		INLET		OUTLET	
Fluid Circulated				TEG/Water(60/40 wt%)				MP Blowdown			
				205102				207611			
Total Fluid	kg/hr										
Vapor	kg/hr		MW								
Liquid	kg/hr		MW	205102		205102		207611		207611	
Steam	kg/hr										
Water	kg/hr							207611		207611	
Noncondensable	kg/hr		MW								
Operating Temperature	°C			40.00		85.00		95.00		60.00	
Operating Pressure	kPaa			994.015				1455.02			
Density	kg/m3		L / v	1078.0		1044.0		962.00		983.00	
Viscosity	cP		L / v	4.6610		1.7770		0.2940		0.4630	
Thermal Conductivity	W/m·°C		L / v	0.3281		0.3381		0.6782		0.6532	
Specific Heat	kJ/kg·°C		L / v	3.2231		3.3841		4.2081		4.1831	
Latent Heat	kJ/kg										
Bubble / Dew Point	°C			/		/		/		/	
Critical Press. / Temp.	kPaa / °C			/		/		/		/	
Velocity	m/sec			0.62				1.68			
Pressure Drop	kPa.			Allow. 120.000		Calc. 107.133		Allow. 165.000		Calc. 163.508	
Fouling Resistance	m <sup>2</sup> ·°C/kW			0.088				0.176			
Film Coefficient	W/m <sup>2</sup> -K			2,482.86				8,993.31			
Overall Coefficient	W/m <sup>2</sup> -K			Clean 1756.50		Calc.		1161.58		Design 1092.47	
Heat Duty	KW			8,469.00				LMTD °C		MTD 12.9 °C	

**CONSTRUCTION**

Design Pressure	Design Temperature	1500.0 / FV kPa.G	-29 / 214 °C	1950.0 / FV kPa.G	-29 / 214 °C
No. of Passes		2		8	
Tubes No.	238U / Shell, Size	31.75 mm	Thickness 2.11 (Min.) mm	( BWG: 14 )	Length 6,096.0 mm
Shell	1120 mm ID	Tube Pitch	39.69 mm	Layout angle 45 °	Effective - mm
Baffles	Cross Baffle 11+1S (Note 2) ea / Shell, Type	Single Seg. (Vert.)	Cut 26.0 % Dia.	Spacing c/c 470.0 mm	End - mm
pv <sup>2</sup>	Inlet Nozzle 641.90	Entrance 1,530.45	Outlet Nozzle 662.81	kg/m·sec <sup>2</sup>	Impingement plate None
Material	Tube SA 179 Seamless	Shell & Cover SA 516 GR. 70N	Channel & Cover SA 516 GR. 70N	Expansion Joint N/A	
	Tube Sheet SA 266 GR.2	Baffle Carbon Steel			
Estimated Weight	Empty Weight	kg	Bundle Weight	- kg	Full Water Weight kg
Corrosion Allowance	Shell side 3.2 mm	Tube side 3.2 mm	Tube Joints: Rolled (two grooves) and Expanded		
Insulation	Shell side 64 mm	Tube side 64 mm	9) Seller is to design and install electrical heat tracing for hold temperature of 10 °C.		

MEAN METAL TEMPERATURE	Temperature, °C				Pressure, kPa.G			
	Shell		Tube		Shell		Tube	
Normal Operating	-		-		-		-	
Startup	-		-		-		-	
NOZZLE	SHELL SIDE				TUBE SIDE			
	Tag	No	NPS	Remarks	Tag	No	NPS	Remarks
Inlet	S1	1	12		T1	1	8	
Outlet	S2	1	12		T2	1	8	
Vent				(Note 8 & 9)				(Note 9)
Drain				(Note 8 & 9)				(Note 9)
Thermowell								
Util. Con.								
RATING	RFWN 300#				RFWN 300#			

CSA approval is required for electric components and installation. The heat exchanger is located in a non-hazardous area.
7) Seller is to supply and install 64mm thick mineral fiber insulation.
8) Each shell and channel shall be provided with a NPS 2" (300#, RFWN or RFLWN) vent and drain. Channel vent & drain between shells shall be provided with a 90° elbow.
Vents and drains shall come complete with blind flange, gasket, bolts & nuts.
9) Each process nozzle shall be provided with one 1" 300# RFLWN (complete with blind flange, gasket, bolts & nuts).
10) Exchangers shall be stacked. Per API 660, exchangers shall be hydrotested stacked.
11) During normal operation 3A-E-325 is not operating. 3A-E-325 operates only when MVC evaporator is down.
12) EHT design shall use voltage of 277 VAC.
13) Bundles shall be removable.

**Remarks**

- 1) Seller shall verify and guarantee thermal rating of the unit.
- 2) Full support at the U-bend tangent line shall be trimmed beyond the top and the bottom tube rows as much as possible.
- 3) Exchanger is to be designed for future field hydrotest in the fully corroded condition.
- 4) Exchangers to be designed for liquid full condition at S.G. = 1.079

- 9) Seller is to design and install electrical heat tracing for hold temperature of 10 °C.
- CSA approval is required for electric components and installation. The heat exchanger is located in a non-hazardous area.
- 7) Seller is to supply and install 64mm thick mineral fiber insulation.
- 8) Each shell and channel shall be provided with a NPS 2" (300#, RFWN or RFLWN) vent and drain. Channel vent & drain between shells shall be provided with a 90° elbow.
- Vents and drains shall come complete with blind flange, gasket, bolts & nuts.
- 9) Each process nozzle shall be provided with one 1" 300# RFLWN (complete with blind flange, gasket, bolts & nuts).
- 10) Exchangers shall be stacked. Per API 660, exchangers shall be hydrotested stacked.
- 11) During normal operation 3A-E-325 is not operating. 3A-E-325 operates only when MVC evaporator is down.
- 12) EHT design shall use voltage of 277 VAC.
- 13) Bundles shall be removable.



SEWON CELLONTECH

## TUBULAR HEAT EXCHANGER

SHEET 3 OF 21

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Blowdown Disposal / Glycol Exchanger	2	-	-	-	09-26-2013
ITEM NO.	3A-E-325A/B (Min Duty Case)					

Total	2	Shells, Connected in	1	Parallel	2	Series Shells	Install	<input checked="" type="checkbox"/> Hor. <input type="checkbox"/> Vert.	Size	1,120.0 ID - 6,096.0 L
Code	ASME Sec.VIII Div.1 (STAMP), TEMA, API660 TEMA Type					AFU	TEMA Class	R	Effective Area	301.34 m <sup>2</sup> /Shell

## PERFORMANCE OF ONE BATTERY

				SHELL SIDE				TUBE SIDE			
				INLET		OUTLET		INLET		OUTLET	
Fluid Circulated				TEG/Water(60/40 wt%)				MP Blowdown			
Total Fluid		kg/hr		152546				154412			
Vapor	kg/hr	MW									
Liquid	kg/hr	MW		152546		152546		154412		154412	
Steam	kg/hr										
Water	kg/hr							154412		154412	
Noncondensible	kg/hr	MW									
Operating Temperature °C				40.00		85.00		95.00		60.00	
Operating Pressure kPaa				994.015				1455.02			
Density	kg/m3	L / v		1078.0		1044.0		962.00		983.00	
Viscosity	cP	L / v		4.6610		1.7770		0.2940		0.4630	
Thermal Conductivity	W/m·°C	L / v		0.3281		0.3381		0.6782		0.6532	
Specific Heat	kJ/kg·°C	L / v		3.2231		3.3841		4.2081		4.1831	
Latent Heat	kJ/kg										
Bubble / Dew Point	°C			/		/		/		/	
Critical Press. / Temp.	kPaa / °C			/		/		/		/	
Velocity	m/sec			0.47		1.25					
Pressure Drop	kPa.			Allow.	100.000	Calc.	62.465	Allow.	100.000	Calc.	93.264
Fouling Resistance	m <sup>2</sup> ·°C/kW			0.088		0.176					
Film Coefficient	W/m <sup>2</sup> -K			2,118.10		7,114.33					
Overall Coefficient	W/m <sup>2</sup> -K			Clean	1487.03	Calc.		1037.21	Design	813.03	
Heat Duty	KW			6,299.00				LMTD	°C	MTD	12.9 °C

## CONSTRUCTION

Design Pressure		Design Temperature		/ kPa.G		/ °C		/ kPa.G		/ °C	
No. of Passes											
Tubes No.		/ Shell, Size		mm		Thickness (Min.) mm		( BWG : )		Length mm	
Shell				mm ID		Tube Pitch mm		Layout angle °		Leffective - mm	
Baffles		Cross Baffle		ea / Shell, Type		Cut		- % Dia.		Spacing c/c mm, End - mm	
pv <sup>2</sup>		Inlet Nozzle		355.08		Entrance		851.35		Outlet Nozzle 366.65 kg/m·sec2	
Material		Tube		Shell & Cover						Impingement plate	
		Tube Sheet		Baffle						Channel & Cover	
										Expansion Joint	
Estimated Weight		Empty Weight		kg		Bundle Weight		kg		Full Water Weight kg	
Corrosion Allowance		Shell side		mm		Tube side		mm		Tube Joints :	
Insulation		Shell side		mm		Tube side		mm		Direct Water Analysis	

MEAN METAL TEMPERATURE	Temperature, °C		Pressure, kPa.G	
	Shell	Tube	Shell	Tube
Normal Operating	-	-	-	-
Startup	-	-	-	-

NOZZLE	SHELL SIDE				TUBE SIDE			
	Tag	No	NPS	Remarks	Tag	No	NPS	Remarks
Inlet								
Outlet								
Vent								
Drain								
Liquid Outlet								
Thermowell								
Util. Con.								
RATING								


## Blowdown Disposal Water Analysis

Water Analysis (mg/l as ion unless noted)		
	Normal	Max.
Ca <sup>++</sup>	0.36	0.44
Mg <sup>++</sup>	0.36	0.44
Na <sup>+</sup>	3707	10709
K <sup>+</sup>	5.92	36.12
Fe <sup>++</sup>	4.47	8.29
Cu <sup>++</sup>	0.22	0.75
Ba <sup>++</sup>	0.31	3.04
Sr <sup>++</sup>	0.89	8.22
HCO <sub>3</sub> <sup>-</sup>	0.0	0.0
CO <sub>3</sub> <sup>-</sup>	127	333
OH <sup>-</sup>	305	775
SO <sub>4</sub> <sup>-</sup>	18.81	39.60
Cl <sup>-</sup>	4929	14529
Silica ppm as SiO <sub>2</sub>	214.1	282.1
Sulphides ppm as S <sup>-</sup>	0.0	0.0
TOC ppm as TOC	0.48	4.83
TDS ppm as ion	9314	26706
TSS ppm TSS	0.0	0.0
Oil & Grease ppm oil in water	0.0	0.0
Total Hardness ppm as CaCO <sub>3</sub>	2.36	2.89
P-Alk (ppm as CaCO <sub>3</sub> )	1004	2559
M-Alk (ppm as CaCO <sub>3</sub> )	1111	2837
Dissolved O <sub>2</sub>	-	-
Estimated pH	12.16	12.61



CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Blowdown Disposal / Glycol Exchanger	2	-	-	-	09-26-2013
ITEM NO.	3A-E-325A/B					

## Shell 1





SEWON CELLONTECH


# TUBULAR HEAT EXCHANGER

SHEET 5 OF 21

CUSTOMER	MEG Energy Corp.
LOCATION	CANADA
JOB NO.	511036
SERVICE	Blowdown Disposal / Glycol Exchanger
ITEM NO.	3A-E-325A/B

REV	MADE BY	CHECKED BY	APPROVED BY	DATE
0	-	-	-	07-01-2013
1	-	-	-	08-14-2013
2	-	-	-	09-26-2013

## Shell 2






**SEWON CELLONTECH****TUBULAR HEAT EXCHANGER**

SHEET 6 OF 21

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Blowdown Disposal / Glycol Exchanger	2	-	-	-	09-26-2013
ITEM NO.	3A-E-325A/B					



3A-E-325  
1/5

I.D.-SHELL	1,120.0 ID	(AFU)
ALLOWABLE O.T.L	1102.2	mm
ACTUAL O.T.L	1102.2	mm
SEAL STRIP	N/A	Pairs
SEAL Rod	N/A	ea

TOTAL 238U HOLES FOR 31.75 OD TUBES ON 39.69 SQUARE PITCH.  
8 PASSES. BAFFLE CUT SINGLE SEGM. 26% DIA.

Remarks

# **Thermal/Hydraulic/ Vibration** **Verification Report**

(Rev.2)

**3A-E-325A/B**

**Client :** MEG Energy Corp.

**Project :** MEG Energy Christina Lake Regional Project  
Phase 3A-Central Plant Facilities

**Date :** 09-26-2013



## 3A-E-325A/B (Max Duty Case)

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer data sheet.

For the design result ( the geometry data), please refer to the Equipment data sheet and Fabrication drawing.

### 1. Thermal and Hydraulic performance

- Thermal performance : 6.33 % Over - Design Case ----- O.K.

- Pressure drop :

Shell-side	<u>107.133</u>	<	120.000 kPa	-----	O.K
tube-side	<u>163.508</u>	<	165.000 kPa	-----	O.K

2

### 2. Vibration Analysis

- Fluidelastic instability : characteristic values << criteria ----- O.K.

- Acoustic vibration : characteristic values << criteria ----- O.K.

- Tube vibration check: characteristic values << criteria ----- O.K.

- Bundle Entrance/Exit : characteristic values << criteria ----- O.K.

- Shell Entrance /Exit: characteristic values << criteria ----- O.K.

9/21

## 3A-E-325A/B (Max Duty Case) - Shell 1

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1690.	940.	908.	2235 (By TEMA)	O.K
Length / TEMA maximum span	0.756	0.421	0.478	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.1033	0.0874	0.1926	< 0.8	O.K
Ave. crossflow velocity ratio	0.0966	0.0817	0.1801	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.077	0.207	0.184	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.158	0.160	< 0.8	O.K
Vortex shedding ratio		0.194	0.197	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.20	1.22	< If velocity is exceed 2.38 / 2.39	O.K.
pv2 (kg/m-s <sup>2</sup> )		1530.45	1551.53	< 5953 by TEMA	O.K.



# Vibration Analysis

Released to the following HTRI Member Company:

sewon  
M.K.Park

Xist Ver. 6.00 SP3 2013/09/13 10:47 SN: 1500213869

MEG Energy Units

Max.Duty Case : Shell 1

Rating - Horizontal Multipass Flow TEMA AFU Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		3.745		
4	Position In The Bundle		Inlet	Center	U-Bend
5	Length for natural frequency	(mm)	1690.	940.	908.
6	Length/TEMA maximum span	(--)	0.756	0.421	0.478
7	Number of spans	(--)	6	6	2
8	Tube natural frequency	(Hz)	35.6	68.6	27.9 +
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		Inlet	Center	U-Bend
11	Window parallel velocity	(m/s)	0.78	0.78	0.78
12	Bundle crossflow velocity	(m/s)	0.15	0.40	0.28
13	Bundle/shell velocity	(m/s)	0.14	0.37	0.26
14	Fluidelastic Instability Check		Inlet	Center	U-Bend
15	Log decrement	HTRI	0.100	0.096	0.100
16	Critical velocity	(m/s)	2.38	7.56	2.39
17	Baffle tip cross velocity ratio	(--)	0.1033	0.0874	0.1926
18	Average crossflow velocity ratio	(--)	0.0966	0.0817	0.1801
19	Acoustic Vibration Check		Inlet	Center	U-Bend
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		Inlet	Center	U-Bend
24	Vortex shedding ratio	(--)	0.077	0.207	0.184
25	Parallel flow amplitude	(mm)	0.003	0.002	0.016
26	Crossflow amplitude	(mm)	0.009	0.007	0.003
27	Tube gap	(mm)	7.940	7.940	7.940
28	Crossflow RHO-V-SQ	(kg/m-s2)	55.97	401.06	194.11
29	Bundle Entrance/Exit			Entrance	Exit
30	(analysis at first tube row)				
31	Fluidelastic instability ratio	(--)		0.158	0.160
32	Vortex shedding ratio	(--)		0.194	0.197
33	Crossflow amplitude	(mm)		0.06105	0.06239
34	Crossflow velocity	(m/s)		0.38	0.38
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			No	
38	Flow area	(m2)		0.045	0.045
39	Velocity	(m/s)		1.20	1.22
40	RHO-V-SQ	(kg/m-s2)		1530.45	1551.53
41	Shell type	AFU	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Parallel	
43	Pitch ratio	1.2501	Tube diameter, (mm)	31.750	
44	Layout angle	45	Tube material	Carbon steel	
45	Number U-Bend supports	1	Supports/baffle space		

## Program Messages

- 47 + Frequency ratios are based upon lowest natural or acoustic frequency
- 48 \* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case
- 49 using the procedure described in Online Help; You may find that a vibration problem is unlikely.



## 3A-E-325A/B (Max Duty Case) - Shell 2

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1690.	940.	908.	2235 (By TEMA)	O.K
Length / TEMA maximum span	0.756	0.421	0.478	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.1032	0.0857	0.1937	< 0.8	O.K
Ave. crossflow velocity ratio	0.0965	0.0802	0.1812	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.077	0.207	0.184	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.157	0.159	< 0.8	O.K
Vortex shedding ratio		0.191	0.195	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.18	1.20	< If velocity is exceed 2.36 / 2.37	O.K.
pv2 (kg/m-s2)		1502.60	1530.45	< 5953 by TEMA	O.K.

**Vibration Analysis**

Released to the following HTRI Member Company:

sewon  
M.K.Park

Xist Ver. 6.00 SP3 2013/09/13 10:47 SN: 1500213869

MEG Energy Units

Max.Duty Case : Shell 2

Rating - Horizontal Multipass Flow TEMA AFU Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		3.745		
4	<b>Position In The Bundle</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
5	Length for natural frequency	(mm)	1690.	940.	908.
6	Length/TEMA maximum span	(--)	0.756	0.421	0.478
7	Number of spans	(--)	6	6	2
8	Tube natural frequency	(Hz)	35.5	68.5	27.8 +
9	Shell acoustic frequency	(Hz)			
10	<b>Flow Velocities</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
11	Window parallel velocity	(m/s)	0.77	0.78	0.78
12	Bundle crossflow velocity	(m/s)	0.15	0.40	0.28
13	Bundle/shell velocity	(m/s)	0.13	0.35	0.24
14	<b>Fluidelastic Instability Check</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
15	Log decrement	HTRI	0.100	0.100	0.100
16	Critical velocity	(m/s)	2.36	7.66	2.37
17	Baffle tip cross velocity ratio	(--)	0.1032	0.0857	0.1937
18	Average crossflow velocity ratio	(--)	0.0965	0.0802	0.1812
19	<b>Acoustic Vibration Check</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	<b>Tube Vibration Check</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
24	Vortex shedding ratio	(--)	0.077	0.207	0.184
25	Parallel flow amplitude	(mm)	0.003	0.002	0.016
26	Crossflow amplitude	(mm)	0.009	0.007	0.003
27	Tube gap	(mm)	7.940	7.940	7.940
28	Crossflow RHO-V-SQ	(kg/m-s2)	56.13	403.10	197.06
29	<b>Bundle Entrance/Exit</b>			<b>Entrance</b>	<b>Exit</b>
30	(analysis at first tube row)				
31	Fluidelastic instability ratio	(--)		0.157	0.159
32	Vortex shedding ratio	(--)		0.191	0.195
33	Crossflow amplitude	(mm)		0.05962	0.06139
34	Crossflow velocity	(m/s)		0.37	0.38
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	<b>Shell Entrance/Exit Parameters</b>			<b>Entrance</b>	<b>Exit</b>
37	Impingement plate			No	
38	Flow area	(m2)		0.045	0.045
39	Velocity	(m/s)		1.18	1.20
40	RHO-V-SQ	(kg/m-s2)		1502.60	1530.45
41	Shell type	AFU	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Parallel	
43	Pitch ratio	1.2501	Tube diameter, (mm)	31.750	
44	Layout angle	45	Tube material	Carbon steel	
45	Number U-Bend supports	1	Supports/baffle space		

**Program Messages**

- 47 + Frequency ratios are based upon lowest natural or acoustic frequency
- 48 \* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case
- 49 using the procedure described in Online Help; You may find that a vibration problem is unlikely.



# Final Results

Released to the following HTRI Member Company:

SEWON


M.K.Park

Xist Ver. 6.00 SP3 2013/09/13 10:47 SN: 1500213869

MEG Energy Units

Max.Duty Case : Shell 1

Rating - Horizontal Multipass Flow TEMA AFU Shell With Single-Segmental Baffles

Process Data					Cold Shellside		Hot Tubeside		Shellside Performance															
2	Fluid name		TEG/Water(60/40 wt%)		MP Blowdown		Sens. Liquid		Sens. Liquid		Nom vel, X-flow/window		0.74 / 0.80											
3	Fluid condition		Sens. Liquid		Sens. Liquid		Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer		0.759											
4	Total flow rate		(kg/hr)		205102		207611		207611		A=0.0183		B=0.7290 C=0.0455 E=0.1424 F=0.0648											
5	Weight fraction vapor, In/Out		(--)		0.000		0.000		0.000		0.000		0.000											
6	Temperature, In/Out		(Deg C)		65.96		85.00		95.00		80.01													
7	Temperature, Average/Skin		(Deg C)		75.48		81.46		87.51		85.77													
8	Wall temperature, Min/Max		(Deg C)		74.05		91.22		74.70		91.61													
9	Pressure, In/Average		(kPa)		939.125		913.004		1455.02		1414.40													
10	Pressure drop, Total/Allowed		(kPa)		52.244		120.000		81.236		165.000													
11	Velocity, Mid/Max allow		(m/s)		0.62				1.69															
12	Mole fraction inert		(--)																					
13	Average film coef.		(W/m2-K)		2644.88				9440.34															
14	Heat transfer safety factor		(--)		1.000				1.000															
15	Fouling resistance		(m2-K/W)		0.000088				0.000176															
16	Overall Performance Data																							
17	Overall coef., Req'd/Clean/Actual		(W/m2-K)		1131.40		/		1854.07		/		1204.33											
18	Heat duty, Calculated/Specified		(kW)		3633.		/																	
19	Effective overall temperature difference		(Deg C)		10.7																			
20	EMTD = (MTD) * (DELTA) * (F/G/H)		(Deg C)		10.82		*		0.9849		*		1.0000											
21																								
22	See Runtime Messages Report for warnings.																							
26	Exchanger Fluid Volumes																							
27	Approximate shellside (L)		3609.5																					
28	Approximate tubeside (L)		3718.6																					
29	Shell Construction Information																							
30	TEMA shell type		AFU		Shell ID		(mm)		1135.00															
31	Shells Series		1 Parallel		1		Total area		(m2)		307.037													
32	Passes Shell		2 Tube		8		Eff. area		(m2/shell)		301.340													
33	Shell orientation angle (deg)		0.00																					
34	Impingement present		No																					
35	Pairs seal strips		0		Passlane seal rods (mm)		31.750		No. 0															
36	Shell expansion joint		No		Full support at U-Bend		No																	
37	Weight estimation Wet/Dry/Bundle		21427.3 /		14104.2 /		6159.16 (kg/shell)																	
38																								
39	Baffle Information																							
40	Type		Parallel Single-Seg.		Baffle cut (% dia)		26.00																	
41	Crosspasses/shellpass		12		No. (Pct Area)		(mm) to C.L																	
42	Central spacing		(mm) 470.000		1		21.38		272.400															
43	Inlet/Outlet Spacing		(mm) 1220.00		2		0.00		0.000															
44	Turn Spacing		(mm) 657.335																					
45	Baffle thickness		(mm) 12.700		Long. baffle length		(mm)		5920.															
46	Insulated long baffle		Yes																					
47																								
48	Tube Information																							
49	Tube type		Plain		Tubecount per shell		476																	
50	Length to tangent		(mm) 6096.		Pct tubes removed (both)		1.26																	
51	Effective length		(mm) 6347.		Outside diameter		(mm)		31.750															
52	Total tubesheet		(mm) 120.000		Wall thickness		(mm)		2.110															
53	Area ratio		(out/in) 1.1533		Pitch (mm)		39.6900		Ratio		1.2501													
54	Tube metal		Carbon steel		Tube pattern (deg)		45																	
										Two-Phase Parameters														
										Method		Inlet		Center		Outlet		Mix F						
										H. T. Parameters					Shell		Tube							
										Overall wall correction					1.016		0.997							
										Midpoint Prandtl no.					21.09		1.99							
										Midpoint Reynolds no.					8671		140382							
										Bundle inlet Reynolds no.					3846		152135							
										Bundle outlet Reynolds no.					7245		127172							
										Fouling layer (mm)														
										Thermal Resistance					Shell		Tube		Fouling		Metal		Over Des	
										45.53					14.71		35.04		4.71		6.45			
										Total fouling resistance					2.908e-4									
										Differential resistance					5.352e-5									
										Shell Nozzles					Inlet		Outlet		Liquid Outlet					
										Inlet at channel end-Yes					1		1		0					
										Number at each position														
										Diameter (mm)					295.301		295.301							
										Velocity (m/s)					0.79		0.80							
										Pressure drop (kPa)					1.010		0.992							
										Height under nozzle (mm)					37.149		37.149							
										Nozzle R-V-SQ (kg/m-s2)					653.80		662.81							
										Shell ent. (kg/m-s2)					1530.45		1551.53							
										Tube Nozzle					Inlet		Outlet		Liquid Outlet					
										Diameter (mm)					193.675		193.675							
										Velocity (m/s)					2.03		2.02							
										Pressure drop (kPa)					2.191		1.381							
										Nozzle R-V-SQ (kg/m-s2)					3983.26		3946.36							
										Annular Distributor					Inlet		Outlet							
										Length (mm)														
										Height (mm)														
										Slot area (mm2)														
										Diametral Clearances (mm)					Baffle-to-shell		Bundle-to-shell		Tube-to-baffle					
										6.3500					17.8000		0.3969							

# Final Results

Released to the following HTRI Member Company:

sewon

M.K.Park

Xist Ver. 6.00 SP3 2013/09/13 10:47 SN: 1500213869

MEG Energy Units

Max.Duty Case : Shell 2

Rating - Horizontal Multipass Flow TEMA AFU Shell With Single-Segmental Baffles

Process Data		Cold Shellside		Hot Tubeside		Shellside Performance	
Fluid name	TEG/Water(60/40 wt%)	MP Blowdown		Sens. Liquid		Nom vel, X-flow/window	0.73 / 0.79
Fluid condition	Sens. Liquid	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer	0.764
Total flow rate	(kg/hr)	205102		207611		A=0.0127 B=0.7368 C=0.0438 E=0.1456 F=0.0612	
Weight fraction vapor, In/Out	(--)	0.000	0.000	0.000	0.000	Shellside Heat Transfer Corrections	
Temperature, In/Out	(Deg C)	40.00	65.97	80.01	60.00	Total	Beta
Temperature, Average/Skin	(Deg C)	52.98	61.77	70.01	67.49	0.986	0.920
Wall temperature, Min/Max	(Deg C)	51.95	74.91	52.78	75.42	Gamma	End
Pressure, In/Average	(kPa)	994.015	966.570	1373.81	1332.67	1.072	0.922
Pressure drop, Total/Allowed	(kPa)	54.890	120.000	82.272	165.000	Fin	1.000
Velocity, Mid/Max allow	(m/s)	0.61		1.67		Pressure Drops (Percent of Total)	
Mole fraction inert	(--)					Cross	Window
Average film coef.	(W/m2-K)	2329.27		8557.15		Ends	Nozzle
Heat transfer safety factor	(--)	1.000		1.000		61.54	25.50
Fouling resistance	(m2-K/W)	0.000088		0.000176		9.20	Inlet
Overall Performance Data						Outlet	1.92
Overall coef., Req'd/Clean/Actual	(W/m2-K)	1053.54	/	1658.92	/	1.84	1.66
Heat duty, Calculated/Specified	(kW)	4836.	/			Two-Phase Parameters	
Effective overall temperature difference	(Deg C)	15.2				Method	Inlet
EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	15.45	*	0.9856	*	Center	Outlet
See Runtime Messages Report for warnings.						Mix F	
Exchanger Fluid Volumes						H. T. Parameters	
Approximate shellside (L)	3609.5					Shell	Tube
Approximate tubeside (L)	3718.6					Overall wall correction	1.027
Shell Construction Information						Midpoint	Prandtl no.
TEMA shell type	AFU	Shell ID	(mm)	1135.00		Midpoint	Reynolds no.
Shells Series	1 Parallel 1	Total area	(m2)	307.037		Bundle inlet	Reynolds no.
Passes Shell	2 Tube 8	Eff. area	(m2/shell)	301.340		Bundle outlet	Reynolds no.
Shell orientation angle (deg)	0.00					Fouling layer	(mm)
Impingement present	No	Passlane seal rods (mm)	31.750	No. 0		Thermal Resistance	
Pairs seal strips	0	Full support at U-Bend	No			Shell	Tube
Shell expansion joint	No					Fouling	Metal
Weight estimation Wet/Dry/Bundle	21430.8 / 14107.7 / 6162.61 (kg/shell)					48.03	15.08
Baffle Information						32.56	4.33
Type	Parallel Single-Seg.	Baffle cut (% dia)	26.00			6.20	
Crosspasses/shellpass	12	No. (Pct Area)	(mm) to C.L			Total fouling resistance	2.908e-4
Central spacing	(mm) 470.000	1	21.38	272.400		Differential resistance	5.54e-5
Inlet/Outlet Spacing	(mm) 1220.00	2	0.00	0.000		Shell Nozzles	
Turn Spacing	(mm) 654.046					Inlet at channel end-Yes	Inlet
Baffle thickness	(mm) 12.700	Long. baffle length	(mm)	5920.		Number at each position	1
Insulated long baffle	Yes					Diameter	(mm) 295.301
Tube Information						Velocity	(m/s) 0.77
Tube type	Plain	Tubecount per shell		476		Pressure drop	(kPa) 1.053
Length to tangent	(mm) 6096.	Pct tubes removed (both)		1.26		Height under nozzle	(mm) 37.149
Effective length	(mm) 6347.	Outside diameter	(mm)	31.750		Nozzle R-V-SQ	(kg/m-s2) 641.90
Total tubesheet	(mm) 120.000	Wall thickness	(mm)	2.110		Shell ent.	(kg/m-s2) 1502.60
Area ratio	(out/in) 1.1533	Pitch (mm)	39.6900	Ratio	1.2501	Tube Nozzle	
Tube metal	Carbon steel	Tube pattern (deg)		45		Inlet	Outlet
						193.675	193.675
						2.02	1.99
						2.171	1.365
						3946.37	3898.16
						Annular Distributor	
						Inlet	Outlet
						Length	(mm)
						Height	(mm)
						Slot area	(mm2)
						Diametral Clearances (mm)	
						Baffle-to-shell	Bundle-to-shell
						6.3500	17.8000
						Tube-to-baffle	
							0.3969

## 3A-E-325A/B (Min Duty Case)

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer DATA SHEET (2).

For the design result ( the geometry data), please refer to the Equipment DATA SHEET (2) and Fabrication drawing.

### 1. Thermal and Hydraulic performance

- Thermal performance : 27.57 % Over - Design Case ----- O.K.

- Pressure drop :

Shell-side	<u>62.465</u>	<	100.000 kPa	-----	O.K
tube-side	<u>93.264</u>	<	100.000 kPa	-----	O.K

### 2. Vibration Analysis

- Fluidelastic instability :	characteristic values	<<	criteria	-----	O.K.
- Acoustic vibration :	characteristic values	<<	criteria	-----	O.K.
- Tube vibration check:	characteristic values	<<	criteria	-----	O.K.
- Bundle Entrance/Exit :	characteristic values	<<	criteria	-----	O.K.
- Shell Entrance /Exit:	characteristic values	<<	criteria	-----	O.K.



## 3A-E-325A/B (Min Duty Case) - Shell 1

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1690.	940.	897.	2235 (By TEMA)	O.K
Length / TEMA maximum span	0.756	0.421	0.475	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0785	0.0664	0.1481	< 0.8	O.K
Ave. crossflow velocity ratio	0.0735	0.0621	0.1386	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.059	0.158	0.140	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.118	0.120	< 0.8	O.K
Vortex shedding ratio		0.145	0.147	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		0.90	0.91	< If velocity is exceed 2.38 / 2.39	O.K.
pv2 (kg/m-s2)		851.35	863.11	< 5953 by TEMA	O.K.

17/21

**Vibration Analysis**

Released to the following HTRI Member Company:

sewon

M.K.Park

Xist Ver. 6.00 SP3 2013/09/13 10:48 SN: 1500213869

MEG Energy Units

Min.Duty Case : Shell 1

Rating - Horizontal Multipass Flow TEMA AFU Shell With Single-Segmental Baffles

1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	3.745		
4	<b>Position In The Bundle</b>	<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
5	Length for natural frequency (mm)	1690.	940.	897.
6	Length/TEMA maximum span (---)	0.756	0.421	0.475
7	Number of spans (---)	6	6	2
8	Tube natural frequency (Hz)	35.6	68.6	28.2 +
9	Shell acoustic frequency (Hz)			
10	<b>Flow Velocities</b>	<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
11	Window parallel velocity (m/s)	0.61	0.61	0.61
12	Bundle crossflow velocity (m/s)	0.11	0.31	0.22
13	Bundle/shell velocity (m/s)	9.731e-2	0.26	0.18
14	<b>Fluidelastic Instability Check</b>	<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
15	Log decrement HTRI	0.100	0.096	0.100
16	Critical velocity (m/s)	2.38	7.56	2.39
17	Baffle tip cross velocity ratio (---)	0.0785	0.0664	0.1481
18	Average crossflow velocity ratio (---)	0.0735	0.0621	0.1386
19	<b>Acoustic Vibration Check</b>	<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
20	Vortex shedding ratio (---)			
21	Chen number (---)			
22	Turbulent buffeting ratio (---)			
23	<b>Tube Vibration Check</b>	<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
24	Vortex shedding ratio (---)	0.059	0.158	0.140
25	Parallel flow amplitude (mm)	0.002	0.001	0.009
26	Crossflow amplitude (mm)	0.005	0.004	0.002
27	Tube gap (mm)	7.940	7.940	7.940
28	Crossflow RHO-V-SQ (kg/m-s2)	32.38	232.01	114.90
29	<b>Bundle Entrance/Exit</b>			
30	(analysis at first tube row)		<b>Entrance</b>	<b>Exit</b>
31	Fluidelastic instability ratio (---)		0.118	0.120
32	Vortex shedding ratio (---)		0.145	0.147
33	Crossflow amplitude (mm)		0.03359	0.03431
34	Crossflow velocity (m/s)		0.28	0.29
35	Tubesheet to inlet/outlet support (mm)		None	None
36	<b>Shell Entrance/Exit Parameters</b>		<b>Entrance</b>	<b>Exit</b>
37	Impingement plate		No	
38	Flow area (m2)		0.045	0.045
39	Velocity (m/s)		0.90	0.91
40	RHO-V-SQ (kg/m-s2)		851.35	863.11
41	Shell type AFU	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Parallel	
43	Pitch ratio 1.2501	Tube diameter, (mm)	31.750	
44	Layout angle 45	Tube material	Carbon steel	
45	Number U-Bend supports 1	Supports/baffle space		

**Program Messages**

+ Frequency ratios are based upon lowest natural or acoustic frequency

\* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case using the procedure described in Online Help; You may find that a vibration problem is unlikely.

2

## 3A-E-325A/B (Min Duty Case) - Shell 2

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1690.	940.	897.	2235 (By TEMA)	O.K
Length / TEMA maximum span	0.756	0.421	0.475	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0781	0.0648	0.1482	< 0.8	O.K
Ave. crossflow velocity ratio	0.0730	0.0607	0.1387	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.058	0.156	0.139	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.117	0.119	< 0.8	O.K
Vortex shedding ratio		0.143	0.146	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		0.88	0.90	< If velocity is exceed 2.36 / 2.37	O.K.
pv2 (kg/m-s2)		835.88	851.35	< 5953 by TEMA	O.K.



# Vibration Analysis

Released to the following HTRI Member Company:

sewon  
M.K.Park

Xist Ver. 6.00 SP3 2013/09/13 10:48 SN: 1500213869

MEG Energy Units

Min.Duty Case : Shell 2

Rating - Horizontal Multipass Flow TEMA AFU Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		3.745		
4	<b>Position In The Bundle</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
5	Length for natural frequency	(mm)	1690.	940.	897.
6	Length/TEMA maximum span	(--)	0.756	0.421	0.475
7	Number of spans	(--)	6	6	2
8	Tube natural frequency	(Hz)	35.5	68.5	28.2 +
9	Shell acoustic frequency	(Hz)			
10	<b>Flow Velocities</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
11	Window parallel velocity	(m/s)	0.60	0.60	0.60
12	Bundle crossflow velocity	(m/s)	0.11	0.30	0.21
13	Bundle/shell velocity	(m/s)	9.999e-2	0.27	0.19
14	<b>Fluidelastic Instability Check</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
15	Log decrement	HTRI	0.100	0.100	0.100
16	Critical velocity	(m/s)	2.36	7.66	2.37
17	Baffle tip cross velocity ratio	(--)	0.0781	0.0648	0.1482
18	Average crossflow velocity ratio	(--)	0.0730	0.0607	0.1387
19	<b>Acoustic Vibration Check</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	<b>Tube Vibration Check</b>		<b>Inlet</b>	<b>Center</b>	<b>U-Bend</b>
24	Vortex shedding ratio	(--)	0.058	0.156	0.139
25	Parallel flow amplitude	(mm)	0.002	0.001	0.009
26	Crossflow amplitude	(mm)	0.005	0.004	0.002
27	Tube gap	(mm)	7.940	7.940	7.940
28	Crossflow RHO-V-SQ	(kg/m-s2)	32.14	230.81	115.47
29	<b>Bundle Entrance/Exit</b>			<b>Entrance</b>	<b>Exit</b>
30	(analysis at first tube row)				
31	Fluidelastic instability ratio	(--)		0.117	0.119
32	Vortex shedding ratio	(--)		0.143	0.146
33	Crossflow amplitude	(mm)		0.03282	0.03377
34	Crossflow velocity	(m/s)		0.28	0.28
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	<b>Shell Entrance/Exit Parameters</b>			<b>Entrance</b>	<b>Exit</b>
37	Impingement plate			No	
38	Flow area	(m2)		0.045	0.045
39	Velocity	(m/s)		0.88	0.90
40	RHO-V-SQ	(kg/m-s2)		835.88	851.35
41	Shell type	AFU	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Parallel	
43	Pitch ratio	1.2501	Tube diameter, (mm)	31.750	
44	Layout angle	45	Tube material	Carbon steel	
45	Number U-Bend supports	1	Supports/baffle space		

## Program Messages

- 47 + Frequency ratios are based upon lowest natural or acoustic frequency
- 48 \* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case
- 49 using the procedure described in Online Help; You may find that a vibration problem is unlikely.



# Final Results

Released to the following HTRI Member Company:

sewon

M.K.Park

Xist Ver. 6.00 SP3 2013/09/13 10:48 SN: 1500213869

MEG Energy Units

Min.Duty Case : Shell 1

Rating - Horizontal Multipass Flow TEMA AFU Shell With Single-Segmental Baffles

Process Data		Cold Shellside		Hot Tubeside		Shellside Performance	
Fluid name	TEG/Water(60/40 wt%)	MP Blowdown		Sens. Liquid		Nom vel, X-flow/window	0.56 / 0.62
Fluid condition	Sens. Liquid	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer	0.763
Total flow rate	(kg/hr)	152546		154412		A=0.0146 B=0.7347 C=0.0436 E=0.1429 F=0.0644	
Weight fraction vapor, In/Out	(--)	0.000	0.000	0.000	0.000		
Temperature, In/Out	(Deg C)	65.93	85.00	95.00	79.98		
Temperature, Average/Skin	(Deg C)	75.46	81.67	87.49	85.54		
Wall temperature, Min/Max	(Deg C)	74.14	91.36	74.72	91.71		
Pressure, In/Average	(kPa)	962.140	946.846	1455.02	1431.88		
Pressure drop, Total/Allowed	(kPa)	30.590	100.000	46.281	100.000		
Velocity, Mid/Max allow	(m/s)	0.47		1.25			
Mole fraction inert	(--)						
Average film coef.	(W/m2-K)	2258.20		7467.84			
Heat transfer safety factor	(--)	1.000		1.000			
Fouling resistance	(m2-K/W)	0.000088		0.000176			
Overall Performance Data						Shellside Heat Transfer Corrections	
Overall coef., Req'd/Clean/Actual	(W/m2-K)	843.17	/	1571.43	/	Total	0.986
Heat duty, Calculated/Specified	(kW)	2708.	/			Beta	0.920
Effective overall temperature difference	(Deg C)	10.7				Gamma	1.072
EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	10.83	*	0.9849	*	End	0.921
						Fin	1.000
						Pressure Drops (Percent of Total)	
						Cross	59.42
						Window	27.28
						Ends	9.56
						Nozzle	1.89
						Inlet	1.85
						Outlet	1.65
						MOMENTUM	
						Two-Phase Parameters	
						Method	
						Inlet	
						Center	
						Outlet	
						Mix F	
						H. T. Parameters	
						Shell	
						Tube	
						Overall wall correction	1.017
						Midpoint	21.10
						Midpoint	6689
						Bundle inlet	2919
						Bundle outlet	5562
						Fouling layer	(mm)
						Thermal Resistance	
						Shell	47.75
						Tube	16.65
						Fouling	31.38
						Metal	4.22
						Over Des	27.89
						Total fouling resistance	2.908e-4
						Differential resistance	2.586e-4
						Shell Nozzles	
						Inlet	
						Outlet	
						Liquid	
						Outlet	
						Inlet	1
						Outlet	1
						Liquid	0
						Number at each position	
						Diameter	(mm)
						Velocity	(m/s)
						Pressure drop	(kPa)
						Height under nozzle	(mm)
						Nozzle R-V-SQ	(kg/m-s2)
						Shell ent.	(kg/m-s2)
						Tube Nozzle	
						Inlet	
						Outlet	
						Liquid	
						Outlet	
						Diameter	(mm)
						Velocity	(m/s)
						Pressure drop	(kPa)
						Nozzle R-V-SQ	(kg/m-s2)
						Annular Distributor	
						Inlet	
						Outlet	
						Length	(mm)
						Height	(mm)
						Slot area	(mm2)
						Diametral Clearances (mm)	
						Baffle-to-shell	6.3500
						Bundle-to-shell	17.8000
						Tube-to-baffle	0.3969



