

SEWON 세원셀론테크(주)	<input checked="" type="checkbox"/> Review <input type="checkbox"/> Witness <input type="checkbox"/> Test
SEWON QC Y.C.HAN	

Handwritten signature
20 Nov 09



☐ Witnessed
☒ Reviewed

Handwritten signature
26. NOV. 09

CRN **U7830.2** A NO.

NB 462

CERTIFIED BY



SEWON CELLONTECH CO., LTD.



1872 Psig AT **350** °F

(M.A.W.P)

W

15 Psig AT **125** °F

(M.A.E.P)

RT1

-20 °F AT **1872 / -15** Psig

(M.D.M.T)

HT



MFR. SERIAL NO. **D0591-002**

YEAR BUILT **2009.04**

PAGE NO.


184/174

L18-5-

 SEWON 세원셀론테크(주)	<input checked="" type="checkbox"/> Review
	<input type="checkbox"/> Witness
	<input type="checkbox"/> Test
SEWON GC Y.C.HAN  26 Mar. '09	



Witnessed
 Release
 26 Mar. '09

207C-309, RECYCLE GAS COMPRESSOR KNOCK OUT DRUM		
CRN		
CODE	ASME SEC. VIII DIV.1 2004 ED. + 2006 ADD. & CSA B51	
PROCESS DESIGN PRESS. (INT./EXT.)	1870[12]/15[F.V]	psig [Mpag]
DESIGN TEMP. (INT./EXT.)	350[176]/125[51]	F [°C]
HYDRO. TEST PRESS. (SHOP)	2544[17] AT 70°F[21°C] MIN.	psig [Mpag]
HYDRO. TEST PRESS. (FIELD)	2434[16] AT 70°F[21°C] MIN.	psig [Mpag]
PNEUM. TEST PRESS.		
FLUID NAME	SOUR & HYDROGEN	
RADIOGRAPHY (S/H)	FULL/FULL	
P.W.H.T	YES	EMPTY W'T 109530[49880] lbs [kg]
DATE BUILT	2009, 0 &	SERIAL NO. D0591-002
FABRICATOR	 SEWON CELLONTECH CO., LTD.	