	<b>CALIBRATION CERTIFICATE</b>		Document No: CALCERT-ASY-0762C-SN-10183526	
			Rev No: A	Date: 10 JUL 2014
			Authorized By: S. ANTE	
	CONFIDENTIAL	Page 1 of 1	Released By: 2288	

## FOCUS® PROBE CALIBRATION CERTIFICATE

DOCUMENT NAME: CALCERT-ASY-0762C-SN-10183526

DATE: 28 JAN 2015


### 1. PRODUCT ID

MANUFACTURER: Photon Control Inc.  
 MODEL#: OFH-INS-3/4-SS-HP-HYB  
 PART#: ASY-0762C  
 SERIAL#: 10183526  
 CORRECTION TABLE: CAL-FIT-INS-148B-NPS6-1R-NOFC-002-10

### 2. TEST

PROCEDURE: CALPROC-ASY-0762C  
 METHOD: COMPARISON  
 MEDIUM: AIR  
 TEMPERATURE: 20°C  
 PRESSURE: 101.85 kPaA  
 RANGE: 0.1 – 12 m/s  
 REFERENCE TEST EQUIPMENT: ABB Total Sonic TS 9048 D-1, SN-04148715

### 3. TEST RESULTS



Velocity [m/s]	MUT Velocity [m/s]	Error As Found [%]	Error As Left [%]
0.562	0.563	+1.37	+0.32
1.720	1.692	+1.28	-1.66
5.078	5.121	+2.96	+0.85
7.460	7.490	+2.13	+0.41
10.140	10.146	+2.35	+0.06
12.386	12.401	+2.28	+0.12
Average Error [%]			+0.017

METER FACTOR: 0.930

TEST DATE: 28-JAN-2015

ISSUED BY: PARMINDER RALH