

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS Page 1 of 3
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by Sewon Cellontech Co., Ltd. 211, Gongdan-ro, Seongsan-gu, Changwon-si, Gyeongsangnam-do 642-370 Republic of Korea
(Name and address of Manufacturer)
2. Manufactured for MEG Energy, 520 - 3 Avenue SW, Calgary, Alberta, Canada, T2P 0R3
(Name and address of Purchaser)
3. Location of installation Canada, Alberta
(Name and address)
4. Type Horizontal Heat Exchanger E0351-020
(Horizontal, vertical, or sphere) (Tank, separator, jkt. vessel, heat exch., etc.) (Manufacture's serial number)
W9302.2 E0351-3AE324-D-01 Rev.<4> 1243 2015
(CRN) (Drawing number) (National Board number) (Year built)
5. ASME Code, Section VIII, Div. 1 2010 ED. + 2011 ADD. N/A N/A
(Edition and Addenda, if applicable (date)) (Code Case number) [Special service per UG-120(d)]

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multichamber vessels.

6. Shell: (a) Number of course(s) 3 (b) Overall length 4080 mm

Course(s)			Material	Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A, B & C)			Heat Treatment	
No.	Diameter	Length	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
2	I.D 850mm	2226.5mm	SA516-70N	12mm	3.2mm	1	Spot	0.85	1	Spot	0.85	-	-
1	I.D 850mm	373mm	SA516-70N	12mm	3.2mm	1	Spot	0.85	1	Spot	0.85	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-

Body Flanges on Shells													
No.	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Location	Bolting				
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material	
1	APP.2	850mm	1006mm	96mm	12mm	SA266-2N	Butt(Type 1)	Shell cover flange	U 1-8UNC x 225mm, 20 Sets	SA193-B7/ SA194-2H	N/A	N/A	
1	APP.2	850mm	1006mm	97mm	12mm	SA266-2N	Butt(Type 1)	Rear end Shell flange	U 1-8UNC x 225mm, 20 Sets	SA193-B7/ SA194-2H	N/A	N/A	
1	APP.2	850mm	1006mm	105mm	12mm	SA266-2N	Butt(Type 1)	Stationary shell flange	U 1-8UNC x 318mm, 28 Sets	SA193-B7/ SA194-2H	N/A	N/A	
-	-	-	-	-	-	-	-	-	-	-	-	-	-

7. Heads: (a) SA516-70N, Seamless(See Remarks 5) (b) N/A
(Material spec. number, grade or type) (H.T. - time and temp.) (Material spec. number, grade or type) (H.T. - time and temp.)

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full, Spot, None	Eff.
(a)	End	10mm	3.2mm	-	-	2:1	-	-	-	-	YES	-	Seamless	1.0
(b)	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Body Flanges on Heads													
	Location	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Bolting				
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material	
(a)	-	-	-	-	-	-	-	-	-	-	-	-	-
(b)	-	-	-	-	-	-	-	-	-	-	-	-	-

8. Type of jacket N/A Jacket closure N/A
(Describe as ogee and weld, bar, etc.)

If bar, give dimensions N/A If bolted, describe or sketch.
9. MAWP 1569 F.V kPag at max. temp. 214 214 °C Min. design metal temp. -29 °C at 1569/F.V kPag
(Internal) (External) (Internal) (External)

10. Impact test Yes, See Remarks 3 at test temperature of See Remarks 3 °C
(Indicate yes or no and the component(s) impact tested)

11. Hydro, pneu., or comb. test pressure 2157 kPag Proof test N/A

Items 12 and 13 to be completed for tube sections.

12. Tubesheet SA266-2N 850 mm 75 mm 6.4mm Bolted
[Stationary (material spec. no.)] [Diameter (subject to press.)] (Nominal thickness) (Corr. allow.) [Attachment (welded or bolted)]
SA266-2N 735 mm 75 mm 6.4mm Bolted
[Floating (material spec. no.)] (Diameter) (Nominal thickness) (Corr. allow.) (Attachment)
13. Tubes SA179 (SEAMLESS) 25.4mm 2.11mm(Min.) 352 Straight
(Material spec. no., grade or type) (O.D.) (Nominal thickness) (Number) [Type (straight or U)]

FORM U-1 (Cont'd)

Page 2 of 3

Items 14-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

14. Shell: (a) No. of course(s) 1 (b) Overall length 836 mm

Course(s)			Material	Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A, B & C)			Heat Treatment	
No.	Diameter	Length	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
1	I.D 850mm	836mm	SA516-70N	12mm	3.2mm	1	Spot	0.85	1	Spot	0.85	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-

Body Flanges on Shells													
No.	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Location	Bolting				Washer Material
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material	
1	APP.2	850mm	1006mm	107mm	12mm	SA266-2N	Butt(Type 1)	Stationary channel flange	U 1-8UNC x 318mm, 28 Sets	SA193-B7/SA194-2H	N/A	N/A	
1	APP.2	850mm	1006mm	107mm	12mm	SA266-2N	Butt(Type 1)	Channel cover flange	U 1-8UNC x 235mm, 28 Sets	SA193-B7/SA194-2H	N/A	N/A	
-	-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-

15. Heads: (a) SA266-2N (b) N/A
(Material spec. number, grade or type) (H.T. - time and temp.) (Material spec. number, grade or type) (H.T. - time and temp.)

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full, Spot, None	Eff.
(a)	End	81mm	3.2mm	-	-	-	-	-	1006mm	-	YES	-	Seamless	1.0
(b)	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Body Flanges on Heads													
	Location	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Bolting				Washer Material
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material	
(a)	-	-	-	-	-	-	-	-	-	-	-	-	-
(b)	-	-	-	-	-	-	-	-	-	-	-	-	-

16. MAWP 2030 F.V kPag at max. temp. 214 214 °C Min. design metal temp. -29 °C at 2030/F.V kPag
(Internal) (External) (Internal) (External)

17. Impact test Yes, See Remarks 3 at test temperature of See Remarks 3 °C
[Indicate yes or no and the component(s) impact tested]

18. Hydro, pneu., or comb. Test pressure 2746 kPag Proof test N/A

19. Nozzle, inspection and safety valve openings

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Type	Material		Nozzle Thickness		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
SHELL SIDE INLET / OUTLET (S1B, S2B)	2	NPS 12	Cl.300 flg.	SA106-B	SA105N	14.27mm	3.2mm	SA516-70N	Fig.UW-16.1 (c)	Butt (Type1), Spot	-
TUBE SIDE INLET / OUTLET (T1B, T2B)	2	NPS 8	Cl.300 flg.	SA106-B	SA105N	12.7mm	3.2mm	SA516-70N	Fig.UW-16.1 (c)	Butt (Type1), None	-
FIELD HYDROTEST (W/B.F) (S3B, S4B)	2	NPS 1	Cl.300 lwn.	SA105N	SA105N	14.25mm	3.2mm	Inherent	Fig.UW-16.1 (c)	Integral	-
FIELD HYDROTEST (W/B.F) (T3B, T4B)	2	NPS 1	Cl.300 lwn.	SA105N	SA105N	14.25mm	3.2mm	Inherent	Fig.UW-16.1 (c)	Integral	-

20. Supports: Skirt No Lugs N/A Legs N/A Others 2-SADDLES Attached Welded to shell
(Yes or no) (Number) (Number) (Describe) (Where and how)

21. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report (list of the name of part, item number, Manufacturer's name and identifying number): N/A

22. Remarks 1. Item No. : 3A-E-324B, Sewon Job No. : E-0351

2. Over pressure protection is provided by others.

3. Impact test for all pressure parts were performed at -29°C for tubesheets, channel cover, except that the impact test of shell, girth flanges, floating head flange, nozzle neck & flange and stud bolt/nuts were exempted as per UCS-66, UG-20(f) and Fig. UCS-66 General Note (c).

4. Pressure retaining cover

S3B, S4B, T3B, T4B: NPS 1 ASME 300# BL.RF, SA105N, Stud B/Heavy Hex. 2NS, SA193-B7/SA194-2H, U5/8-11UNCx90mm, 4 Sets/each.

5. Stress relieving heat treatment was performed for shell cover head for 2hrs. at 622~640 °C.

6. PWHT was performed for floating head to floating head flange joint weld for 1.8hrs. at 630~645 °C.

7. Floating head to floating head flange joint weld(FH-01) was fully radiography examined.

Nation Board No. : 1243
Mfg. Representative: J. A. Pak Date: Feb. 3 '16
Authorized Inspector: _____ Date: _____

FORM U-1 (Cont'd)

Page 3 of 3

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1.

U Certificate of Authorization Number 22,125 Expires Aug. 25, 2017
Date Feb. 3 '16 Name Sewon Cellontech Co., Ltd. Signed J. A. Pak
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by HSB Global Standards of Hartford CT, and have inspected the pressure vessel described in this Manufacturer's Data Report on _____, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) [National Board (incl. endorsements)]

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the statements in this report are correct and that the field assembly construction of all parts of this vessel conforms with the requirements of ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. U Certificate of Authorization Number _____ Expires _____

Date _____ Name _____ Signed _____
(Assembler) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by _____ of _____, have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) [National Board (incl. endorsements)]